

PROVINCE OF BRITISH COLUMBIA
REGULATION OF THE MINISTER OF FORESTS AND RANGE
AND MINISTER RESPONSIBLE FOR HOUSING

Fire Services Act

Ministerial Order No. **N 256**

I, Rich Coleman, Minister of Forests and Range and Minister Responsible for Housing, order that the Schedule to B.C. Reg. 175/2006 is amended as set out in the attached Schedule.

October 17/2006
Date


Minister of Forests and Range and
Minister Responsible for Housing

(This part is for administrative purposes only and is not part of the Order.)

Authority under which Order is made:

Act and section:- Fire Services Act, R.S.B.C. 1996, c. 144, s. 47 (2)

Other (specify):- M137/2006

SCHEDULE

1 *Item 74 of the Schedule to B.C. Reg. 175/2006 is repealed and the following substituted:*

74	5.3.1.2.(2)	<p>Replace with the following:</p> <p>2) When used in an atmosphere containing <i>combustible dusts</i>, the cleaning equipment required in Sentence (1) shall conform to the, British Columbia Safety Standards Act and pursuant regulations.</p>
----	-------------	--

2 *The following items are added after item 74:*

75	5.3.1.2.(3)(b)	<p>Replace with the following:</p> <p>b) all machinery and equipment is de-energized, unless such equipment is suitable for use in atmospheres containing <i>combustible dusts</i>, in conformance with the British Columbia Safety Standards Act and pursuant regulations.</p>
76	5.3.1.10.(2)	<p>Replace with the following:</p> <p>2) Portable electrical equipment used in atmospheres containing <i>combustible dusts</i> shall conform to the British Columbia Safety Standards Act and pursuant regulations.</p>
77	5.5.3.4.(1)	<p>Replace with the following:</p> <p>1) Except as provided in Sentence 5.5.3.5.(3), electrical equipment located in areas where the concentration of flammable vapours is sufficient to create a hazard shall conform to the British Columbia Safety Standards Act and pursuant regulations, for the hazardous locations.</p>
78	5.6.1.10.(2)	<p>Replace with the following:</p> <p>2) Temporary electrical installations shall be installed in conformance with the British Columbia Safety Standards Act and pursuant regulations.</p>
79	5.6.1.11.(3)	<p>Replace with the following:</p> <p>3) The clearance between combustible materials and temporary heating equipment, including <i>flues</i>, shall be in conformance with Part 6 of the British Columbia Building Code or in conformance with the minimum clearances shown on certified heating equipment.</p>
80	5.6.1.12.(1) (a) and (b)	<p>Replace with the following:</p> <p>a) CAN/CSA-B139-M, "Installation Code for Oil Burning Equipment," the British Columbia Building Code, or</p> <p>b) the British Columbia Safety Standards Act and pursuant regulations.</p>

81	5.6.1.19.(1)	Replace with the following: 1) Combustible refuse in sufficient quantities to constitute a fire hazard shall be moved to a safe location. (See also Subsection 8.2.5. of the British Columbia Building Code.)
82	6.4.2.	Insert Subsection 6.4.2. Standard Fire Hose Thread as follows: